

Consumer Confidence Report – 2025 Covering Calendar Year – 2024

LATIMER CO. RWD #2 OK3003903

This report is a snapshot of the quality of the water that we provided last year. Included are the details about where your water comes from, what it contains, and how it compares to Environmental Protection Agency (EPA) and state standards. We are committed to providing you with information because informed customers are our best allies.

For access to the LATIMER CO. RWD #2 service line inventory, or if you would like to be actively involved in the decision-making processes that affect drinking water quality, please call LATIMER CO. RWD #2 at 918-522-4272.

Our drinking water is supplied from another water system through a Consecutive Connection (CC). To find out more about our drinking water sources and additional chemical sampling results, please contact our office at the number provided above. Your water comes from :

Buyer Name	Seller Name
LATIMER CO. RWD #2	TALIHINA PWA
LATIMER CO. RWD #2	SARDIS LAKE WATER AUTHORITY

Some people may be more vulnerable to contaminants in drinking water than the general population. Immuno-compromised persons such as those with cancer undergoing chemotherapy, persons who have undergone organ transplants, people with HIV/AIDS or other immune system disorders, some elderly, and infants can be particularly at risk from infections. These people should seek advice about drinking water from their health care providers. EPA/CDC guidelines on appropriate means to lessen the risk of infection by *Cryptosporidium* and other microbial contaminants are available from the Safe Drinking Water Hotline (800-426-4791).

Drinking water, including bottled water, may reasonably be expected to contain at least small amounts of some contaminants. The presence of contaminants does not necessarily indicate that water poses a health risk. More information about contaminants and potential health effects can be obtained by calling the EPA's Safe Drinking Water Hotline (800-426-4791).

The sources of drinking water (both tap water and bottled water) include rivers, lakes, streams, ponds, reservoirs, springs, and wells. As water travels over the surface of the land or through the ground, it dissolves naturally occurring minerals and, in some cases, radioactive material, and can pick up substances resulting from the presence of animals or from human activity. Please contact us to obtain more information about a source water assessment and its availability.

Contaminants that may be present in source water before we treat it include:

Microbial contaminants, such as viruses and bacteria, which may come from sewage treatment plants, septic systems, livestock operations and wildlife.

Inorganic contaminants, such as salts and metals, which can be naturally-occurring or result from urban storm water runoff, industrial or domestic wastewater discharges, oil and gas production, mining or farming.

Pesticides and herbicides, which may come from a variety of sources such as storm water run-off, agriculture, and residential users.

Radioactive contaminants, which can be naturally occurring or the result of mining activity.

Organic contaminants, including synthetic and volatile organic chemicals, which are by-products of industrial processes and petroleum production, and also come from gas stations, urban storm water run-off, and septic systems.

In order to ensure that tap water is safe to drink, EPA prescribes regulations which limits the amount of certain contaminants in water provided by public water systems. We treat our water according to EPA's regulations. Food and Drug

Administration regulations establish limits for contaminants in bottled water, which must provide the same protection for public health.

Our water system is required to test a minimum of 2 samples per month in accordance with the Total Coliform Rule for microbiological contaminants. Coliform bacteria are usually harmless, but their presence in water can be an indication of disease-causing bacteria. When coliform bacteria are found, special follow-up tests are done to determine if harmful bacteria are present in the water supply. If this limit is exceeded, the water supplier must notify the public.

Water Quality Data

The following tables list all of the drinking water contaminants which were detected during the 2024 calendar year. The presence of these contaminants does not necessarily indicate the water poses a health risk. Unless noted, the data presented in this table is from the testing done January 1- December 31, 2024. The state requires us to monitor for certain contaminants less than once per year because the concentrations of these contaminants are not expected to vary significantly from year to year. Some of the data, though representative of the water quality, is more than one year old.

Terms & Abbreviations

Maximum Contaminant Level Goal (MCLG): the "Goal" is the level of a contaminant in drinking water below which there is no known or expected risk to human health. MCLGs allow for a margin of safety.

Maximum Contaminant Level (MCL): the "Maximum Allowed" MCL is the highest level of a contaminant that is allowed in drinking water. MCLs are set as close to the MCLGs as feasible using the best available treatment technology.

Secondary Maximum Contaminant Level (SMCL): recommended level for a contaminant that is not regulated and has no MCL.

Action Level (AL): the concentration of a contaminant that, if exceeded, triggers treatment or other requirements.

Treatment Technique (TT): a required process intended to reduce levels of a contaminant in drinking water.

Maximum Residual Disinfectant Level (MRDL): the highest level of a disinfectant allowed in drinking water. There is convincing evidence that addition of a disinfectant is necessary for control of microbial contaminants.

Non-Detects (ND): lab analysis indicates that the contaminant is not present.

Parts per Million (ppm) or milligrams per liter (mg/l)

Parts per Billion (ppb) or micrograms per liter (µg/l)

Picocuries per Liter (pCi/L): a measure of the radioactivity in water.

Millirems per Year (mrem/yr): measure of radiation absorbed by the body.

Monitoring Period Average (MPA): An average of sample results obtained during a defined time frame, common examples of monitoring periods are monthly, quarterly and yearly.

Nephelometric Turbidity Unit (NTU): a measure of the clarity of water. Turbidity in excess of 5 NTU is just noticeable to the average person. Turbidity is not regulated for groundwater systems.

Running Annual Average (RAA): an average of sample results obtained over the most current 12 months and used to determine compliance with MCLs.

Locational Running Annual Average (LRAA): Average of sample analytical results for samples taken at a particular monitoring location during the previous four calendar quarters.

Monitoring and Reporting (M/R): a violation for failure to conduct regular monitoring of drinking water quality or to submit monitoring results in a timely fashion.

Operational Evaluation Level (OEL): a report triggered by the disinfection by-products rule.

Testing Results for: LATIMER CO. RWD #2

Please Note: Because of sampling schedules, results may be older than 1 year

Disinfection Byproducts	Monitoring Period	Highest RAA	Range (low/high)	Unit	MCL	MCLG	Typical Source
TOTAL HALOACETIC ACIDS (HAA5)	2024	54	0 - 57.4	ppb	60	0	By-product of drinking water disinfection
TTHM	2024	191	34.5 - 154.5	ppb	80	0	By-product of drinking water disinfection

Lead and Copper	Monitoring Period	90 th Percentile	Range (low/high)	Unit	AL	Sites Over AL	Typical Source
COPPER, FREE	2024	0.208	0.00362 - 0.606	ppm	1.3	0	Corrosion of household plumbing systems; Erosion of natural deposits; Leaching from wood preservatives.
LEAD	2024	1.75	0 - 4.89	ppb	15	0	Corrosion of household plumbing systems; Erosion of natural deposits.

If present, elevated levels of lead can cause serious health problems, especially for pregnant women and young children. Lead in drinking water is primarily from materials and components associated with service lines and home plumbing. Your water system is responsible for providing high quality drinking water, but cannot control the variety of materials used in plumbing components. When your water has been sitting for several hours, you can minimize the potential for lead exposure by flushing your tap for 30 seconds to 2 minutes before using water for drinking or cooking. If you are concerned about lead in your water, you may wish to have your water tested. Information on lead in drinking water, testing methods, and steps you can take to minimize exposure is available from the Safe Drinking Water Hotline or at <http://www.epa.gov/safewater/lead>.

Chlorine/Chloramines Maximum Disinfection Level	MPA	MPA Units	RAA	RAA Units
01/01/2024 - 01/31/2024	1.77	MG/L	1.3	MG/L

Secondary Contaminants-Non Health Based Contaminants-No Federal Maximum Contaminant Level (MCL) Established.	Collection Date	Highest Value	Range (low/high)	Unit	SMCL
ALKALINITY, TOTAL	6/20/2024	27.9	2 - 27.9	MG/L	
CALCIUM	11/21/2024	5.04	3.41 - 5.04	MG/L	
CONDUCTIVITY @ 25 C UMHOS/CM	6/20/2024	110	77 - 110	UMHO/CM	
ORTHOPHOSPHATE	11/21/2024	0.428	0 - 0.428		
PH	6/20/2024	8.8	6.4 - 8.8	PH	8.5
TEMPERATURE (CENTIGRADE)	6/20/2024	27.4	15.9 - 27.4	C	

During the 2024 calendar year, we had the below noted violation(s) of drinking water regulations.

Compliance Period	Analyte	Comments
6/30/2024 - 12/4/2024	TTHM	FAILURE SUBMIT OEL REPORT FOR TTHM
1/1/2024 - 3/31/2024	TTHM	MCL, LRAA
4/1/2024 - 6/30/2024	TTHM	MCL, LRAA
7/1/2024 - 9/30/2024	TTHM	MCL, LRAA
10/1/2024 - 12/31/2024	TTHM	MCL, LRAA
1/1/2024 - 6/30/2024	WQP+ORTHOPHOSPHATE	WATER QUALITY PARAMETER M/R (LCR)

Additional Required Health Effects Language:

Some people who drink water containing trihalomethanes in excess of the MCL over many years may experience problems with their liver, kidneys, or central nervous systems, and may have an increased risk of getting cancer.

Some or all of our drinking water is supplied from another water system. The table below lists all of the drinking water contaminants, which were detected during the 2024 calendar year from the water systems that we purchase drinking water from.

Regulated Contaminants	Collection Date	Water System	Highest Value	Range (low/high)	Unit	MCL	MCLG	Typical Source
BARIUM	4/13/2021	TALIHINA PWA	0.0311	0.0311	ppm	2	2	Discharge of drilling wastes; Discharge from

								metal refineries; Erosion of natural deposits.
COMBINED RADIUM (-226 & -228)	1/9/2024	TALIHINA PWA	0.339	0.339	pCi/L	5	0	Erosion of natural deposits
GROSS ALPHA, EXCL. RADON & U	1/9/2024	TALIHINA PWA	0.166	0.166	pCi/L	15	0	Erosion of natural deposits
NICKEL	4/13/2021	TALIHINA PWA	0.00077	0.00077	MG/L			

Secondary Contaminants	Collection Date	Water System	Highest Value	Range (low/high)	Unit	SMCL
ALKALINITY, TOTAL	6/7/2021	SARDIS LAKE WATER AUTHORITY	16.2	10.9 - 16.2	MG/L	
CALCIUM	6/7/2021	SARDIS LAKE WATER AUTHORITY	3.77	3.15 - 3.77	MG/L	
CONDUCTIVITY @ 25 C UMHOS/CM	6/7/2021	SARDIS LAKE WATER AUTHORITY	75	64.5 - 75	UMHO/CM	
PH	4/12/2021	SARDIS LAKE WATER AUTHORITY	7.7	6.4 - 7.7	PH	8.5
SODIUM	1/9/2024	TALIHINA PWA	8.7	8.7	MG/L	
TEMPERATURE (CENTIGRADE)	10/12/2021	SARDIS LAKE WATER AUTHORITY	23.4	17.7 - 23.4	C	

During the 2024 calendar year, the water systems that we purchase water from had the below noted violation(s) of drinking water regulations.

Water System	Type	Category	Analyte	Compliance Period
TALIHINA PWA	INADEQUATE DBP PRECURSOR REMOVAL	TT	CARBON, TOTAL	6/1/2024 - 6/30/2024
TALIHINA PWA	INADEQUATE DBP PRECURSOR REMOVAL	TT	CARBON, TOTAL	9/1/2024 - 9/30/2024
TALIHINA PWA	MONITORING, ROUTINE (DBP), MAJOR	MON	CHLORINE	1/1/2024 - 1/31/2024
TALIHINA PWA	MONITORING, ROUTINE (DBP), MAJOR	MON	CHLORINE	5/1/2024 - 5/31/2024
TALIHINA PWA	MONITORING, ROUTINE, MINOR (RTCR)	MON	E. COLI	1/1/2024 - 1/31/2024
TALIHINA PWA	MONITORING, ROUTINE, MINOR (RTCR)	MON	E. COLI	5/1/2024 - 5/31/2024
SARDIS LAKE WATER AUTHORITY	MCL, LRAA	MCL	TOTAL HALOACETIC ACIDS (HAA5)	1/1/2024 - 3/31/2024
SARDIS LAKE WATER AUTHORITY	MONTHLY COMB FLTR EFFLUENT (IESWTR/LT1)	TT	TURBIDITY	4/1/2024 - 4/30/2024

IMPORTANT INFORMATION ABOUT YOUR DRINKING WATER

LATIMER CO. RWD #2 Did Not Meet Monitoring Requirements

Our water system violated drinking water requirements pertaining to the contaminant(s) of concern listed below. Although none of these violations are considered emergencies, as our customers, you have a right to know what happened and what we are doing, or have done, to correct these violations. Customers are not at risk and there is no reason to suspect any potential adverse health effects. Alternative water supplies are not needed.

We are required to monitor your drinking water for specific contaminants on a regular basis. Results of regular monitoring are an indicator of whether or not your drinking water meets health standards. During the following monitoring periods, we did not monitor or test for the following contaminants, and therefore cannot be sure of the quality of your drinking water during that time:

<u>Contaminant</u>	<u>Begin Date</u>	<u>End Date</u>	<u># of Samples Required</u>	<u># of Samples Missing</u>
WATER QUALITY PARAMETER	1/1/2024	6/30/2024	4	2

What should I do? There is nothing you need to do at this time.

What happened? What is being done? We missed taking several samples. We have or will take the samples in the future.

We anticipate resolving the problem: The problem has been resolved or will be resolved as soon as the samples are taken.

For more information, please contact: Cheryl Henry, Chairperson at 918-522-4272 or 5473 S.E. Hwy 63, TALIHINA OK, 74571

Please share this information with all the other people who drink this water, especially those who may not have received this notice directly (for example, people in apartments, nursing homes, schools, and businesses). You can do this by posting this notice in a public place or distributing copies by hand or mail.

Monitoring Public Notice

OK3003903

Date Distributed: _____